

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 99/SF1(S)/24-25

Date : 28/02/24

It is certified that an inspection team*headed by Sumit Mishra
Sanitary and Food Inspector (Name of Officers
 with designation) from Lucknow Municipal Corporation (Name of
 Department/Office) inspected the DELHI PUBLIC SCHOOL, ELDECO, Lucknow
 (Name & Address of
 the School) on 28/02/2024 and found that the DELHI PUBLIC SCHOOL
Eldeco, Lucknow (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 (one) year.

Signature with Seal :

Name

Designation

सुमित मिश्रा
 सफाई एवं खाद्य निरीक्षक
 नगर, निगम, लखनऊ, जोन-08
 मो- 8810721643

: Sumit Mishra

: Sanitary and Food Inspector

To

DELHI PUBLIC SCHOOL
ELDECO, Rae Bareilly Road
Lucknow

(Name & Address of the Institution)

Principal
Delhi Public School
Raksha Khand-II, Udyan-II
Raibareilly Road, Lucknow

Manager
Delhi Public School
Raksha Khand-II, Udyan-II
Raibareilly Road, Lucknow

GEOGREEN TESTING LABORATORY

NABL ACCREDITED LABORATORY

Laboratory : C 1/20, Viraj Khand, Gomti Nagar Lucknow - 226010 (U.P.)
Phone : +91 9415215163, 9161202020 Email : geogreen.ll@gmail.com
Website : www.geogreen.in



Certi. No. TC9995

TEST REPORT

Format No.GTL/SF/50


Sample Code No.	GTL/WS/3626	Report No.	WS22042024-3626
Sample Code Given By Client	None	Issue Date	22/04/2024
Sample Drawn by	Client	Condition of the Sample	Sealed
Sample Drawn on	19/04/2024	Nature of Sample	Drinking Water
Sample Received on	19/04/2024	Test Duration	19/04/2024-22/04/2024
Sampling Location	At School	Sample Quantity	2 liter
Client's Name & Address	M/s Delhi Public School Udyan II, Raksha Khand, Eldeco, Raibareilly Road, Lucknow , Uttar Pradesh		

S. No.	Parameter Tested	Units	Result	Desirable Limits	Maximum Permissible Limits	Test Protocol
				(IS 10500:2012) Second revision		
1	pH Value	-	7.52	6.5 - 8.5	No Relaxation	APHA 4500- H ⁺ ,B
2	Turbidity	NTU	1.5	1.00	5.0	APHA 2130 B
3	Electrical Conductivity	µs/cm	897.0	-	-	APHA 2510 B
4	Total Suspended Solids	mg/L	4.0	-	-	APHA 2540 D
5	Total Dissolve Solid	mg/L	460.0	500	2000	APHA 2540
6	Total Solids	mg/L	464.0	-	-	APHA 2540 B
7	Total hardness as CaCO ₃	mg/L	378.0	200.0	600.0	APHA 2340-A
8	Calcium as Ca	mg/L	61.72	75	200.0	APHA 3500-Ca B
9	Magnesium as Mg	mg/L	54.73	30	100	APHA 3500 B
10	Alkalinity as CaCO ₃	mg/L	396.0	200.0	600.0	APHA 2320 B
11	Chlorides as CL ⁻	mg/L	39.99	250.0	1000.0	APHA 4500 CL ⁻ B
12	Sulphate as SO ₄ ²⁻	mg/L	36.23	200.0	400.0	APHA 4500 -SO ₄ ²⁻ E
13	Nitrate as NO ₃	mg/L	12.5	45.0	No Relaxation	IS 3025 (Part 34)
14	Iron as Fe	mg/L	0.1	0.3	No Relaxation	APHA 3500 Fe B
15	Fluoride as F ⁻	mg/L	0.57	1.0	1.5	APHA 4500 F ⁻ D
16	Sodium as Na	mg/L	15.1	-	-	APHA 3500 Na A
17	Potassium as K	mg/L	11.0	-	-	APHA 3500 K , B
18	Residual Free Chlorine	mg/L	BDL	1.0	1.5	APHA 4500 B

Shalin

Shalin
Principal
Delhi Public School
Raksha Khand-II, Udyan-II
Raibareilly Road, Lucknow

Manish Barik
Manager
Delhi Public School
Raksha Khand-II, Udyan-II
Raibareilly Road Lucknow



MICROBIOLOGICAL PARAMETERS


1.	Total Coliform	MPN/100ml	Absent	Absent	Absent	IS: 1622-1981
2.	Faecal Coliform	MPN/100ml	Absent	Absent	Absent	IS: 1622-1981

- Portable water is suitable for human consumption.
- The requirement mentioned here as per IS 10500: 2012 Drinking water specification
- Conformity statement: the sample complies to IS 10500: 2012 Drinking water specification with respect to above parameter tested.

NOTE:


1. The results given above are related to the tested sample, for various parameters, as observed at the time of sampling. The customer asked for the above tests only.
2. The test samples will be disposed off after 15 days from the date of issue of test report, unless until specified by the customer.

Shalini
Checked by


Principal
Delhi Public School
Raksha Khand-II, Udyan-II
Raibareilly Road, Lucknow

For Geogreen Testing Laboratory


Dr. Vijay Kumar Mishra
Quality Manager
(Authorized Signatory)


Manager
Delhi Public School
Raksha Khand-II, Udyan-II
Raibareilly Road Lucknow